

UTILITY COMPANY: Ameren CILCO (formerly Central Illinois Power Co) (877) 677-5740

CONTACT INFO: Peoria - Trish Rawls: (309) 444-7913 / (309) 256-6410 mobile \* Allen Getz: (309) 693-4686 / (309) 256-6580 mobile

Peoria - Bill Rosecrans: (309) 693-4787

Primary Conduit Rules: install per project manager specification


Secondary Conduit Rules: Ameren CILCO doesn't require rigid above grade, but our customers and inspectors might

Riser Rules: Install full riser on pole. 10' rigid or SCH 80 with PVC above that with a weatherhead. Verify no rigid with inspector.

Wire Rules: we pull wire for 200 amp service

Pad-Mount Transformers: do we intall lugs -yes, compression. Watchman? - 2 days notice  
 Springfield - they connect @ pad -- more notes in here please !!! ???

Meter Socket: Lever bypass meter socket per specifications. No pedestals! CILCO needs to know the multi-meter position we occupy and so does the inspector! Meter sockets must be labeled 1,2,3,4,5,6 or A,B,C,D,E,F



TRINITY TECHNOLOGIES LLC - 4602 PFLAUM ROAD - MADISON, WI 53718 - (608) 221-2333