

UTILITY COMPANY: Ameren IP (formerly Illinois Power) 800 892 7715 Construction Dept: (800) 363-6805

CONTACT INFO: Bloomington: Cindi Smith - (309) 826-0846

Decatur: Debbie - (271) 424-6416 office/Tammie: (217) 412-6455 field engineer

Champaign: Ron Schneider - (217) 778-0733

Primary Conduit Rules: Install per project manager specifications


Secondary Conduit Rules: 3" below grade & 3" risers, RIGID SWEEP 36" ELBOWS. Our customers may require rigid above grade. Find out if AMEREN IP requires rigid above grade !

Riser Rules: Install 10' rigid riser on pole. AMEREN must install their own standoffs. We supply 10' PVC that AMEREN installs on pole

Wire Rules: AMEREN pulls wire for a 200 amp service. Install a 600 lb. pull-rope. What are multi-gang rules/specs?

Pad-Mount Transformers: do we install lugs? Label sockets A, B, C, D - communicate to inspector & power co.

Meter Socket: Lever bypass meter socket. Since they pull wire, they probably have a certain meter socket they prefer us to use. What is that part number ? AMEREN needs to know which multi-meter position we are in - needs to be marked.



TRINITY TECHNOLOGIES LLC - 4602 PFLAUM ROAD - MADISON, WI 53718 - (608) 221-2333